

# Sorption cold energy storage device for solar cooling applications

**Dr. Eng. Salvatore Vasta, PhD.**

*Research Engineer  
Thermally Driven Heat Pumps*

Consiglio Nazionale delle Ricerche (CNR)

Istituto di Tecnologie Avanzate per l'Energia "Nicola Giordano" (ITAE)






*Via Salita S. Lucia sopra Contesse n. 5  
98126, Messina, ITALY*

P: +39.090.624.404/296 - F: +39.090.624.247






Skype: salvo-vasta

W: [www.itae.cnr.it](http://www.itae.cnr.it) - E: [salvatore.vasta@itae.cnr.it](mailto:salvatore.vasta@itae.cnr.it)




# IDEA & CONCEPT

-  Design and realize a Solar Sorption Cold Storage based on a Zeolite/Water pair
-  Define an assessment procedure to characterize the SCS
-  Test the system and the procedure
-  Analyze the data
-  Improve the prototype and the assessment procedure

# SUMMARY

-  **Sorption Cold (Heat) Storage requirements and constrains (FULL SCALE)**
-  **Lab Scale system sizing and design**
-  **Lab Scale system realization**
-  **Tests**
-  **Discussion on results**


# HOW SHOULD IT WORK?




Consiglio Nazionale delle Ricerche

# APPLICATIONS


## 1: Cooling of Telecommunication shelters trough solar heat



## 2: Booster for air-conditioning systems




## 3. Other mobile/stationary application



# REQUIREMENTS & CONSTRAINTS

## FULL SCALE

Product	Parameter	Value	Unit	
	Storage Capacity	2	kWh	
	Discharge Time	2	h	
	Avg. Power	1	kW	
	Water needed	2.9	l	
<b>Design temperatures</b>		Adsorber	Phase Changer	
Charge	95	°C	35	°C
Discharge	35	°C	10	°C
Useful ΔX	15%			
Ext. Amount of zeolite	19.4	kg		



## LAB SCALE


Prototype	Parameter	Value	Unit
	Portion of Product	25%	
	Storage Capacity	500	Wh
	Avg. Power	250	W

Adsorber design			
		Theoretical	Real
Total Capacity	Wh	500	636.40
Total Capacity	kJ	1800	2291.04
Water to be evaporated	kg	0.727	0.925
Expected adsorption capacity	kg/kg	0.15	0.15
Minimum zeolite mass	kg	4.85	6.17

87 W  
Thermal  
Losses @  
nominal  
conditions

# SYSTEM REALIZATION

DESORBER/ADSORBER



Consiglio Nazionale delle Ricerche



Zeolite FAM Z02  
Grains  
1 – 2 mm dia.



EXCHANGER mass	5595 g
ZEOLITE mass	4476 g




- 28 % respect to the design (6.17 kg)

# SYSTEM REALIZATION/2


## Phase Changer

- **Cu/SS finned tube HEXs**
- **SS chambers**
- **Design nominal power: 3.5 kW**
- **Measured evap/condensing Power: up to 3 kW**





# SYSTEM REALIZATION/3



## MONITORED PARAMETERS

- T in/out Adsorber
- T in/out Phase Changer (CON/EVAP)
- T liquid phase into Phase Changer
- Adsorber loop flow rate
- Phase Changer loop flow rate
- Adsorber pressure
- Phase Changer Pressure
- T shell
- T ambient

# SYSTEM REALIZATION/4 - Dimensions



## Adsorber

<b>Overall dimensions [mm]</b>	250 x 553 x 774
<b>Internal dimensions of the chamber [mm]</b>	240 x 543 x 769
<b>Cover dimensions</b>	308 x 613 x 10
<b>Connections on the cover</b>	-2 x $\frac{3}{8}$ '' pipes for the connection of the hydraulic circuits -1 x $\frac{1}{4}$ '' connection for the thermocouple -1 x DN 16 vacuum flange for the connection of a pressure sensor -1 x DN 16 vacuum flange for the vacuum circuit
<b>Connections on the chamber</b>	-2 x DN50 connections for the connection with the phase changer (or 2 phase changers in case of future expansions)
<b>Material</b>	AISI316

## Phase Changer


<b>Overall dimensions [mm]</b>	304 x 177 x 298
<b>Internal dimensions of the chamber [mm]</b>	302 x 175 x 296
<b>Heat exchangers</b>	4 x copper/SS tube-and-fin heat exchangers
<b>Connections on the chamber: front</b>	-2 x $\frac{3}{8}$ '' pipes for the connection of the hydraulic circuits -1 x $\frac{1}{4}$ '' connection for the thermocouple -1 x DN 16 vacuum flange for the connection of a pressure sensor -1 x DN 16 vacuum flange for the vacuum circuit
<b>Connections on the chamber: lateral</b>	-2 x DN50 connections for the connection with the adsorber (or 2 adsorbers in case of future expansions)
<b>Material</b>	AISI316

# TESTS – Testing bench description




## Features


- Variable flow hydraulic pumps
- High accuracy sensors
- Pressure drop measurements
- Simple/heat recovery cycle operation
- 16 kW electric heater (@95 °C MAX)
- 0 – 20 °C LT simulation ability
- 15 – 50 °C MT simulation ability




# TESTS – Assessment procedure description



# TESTS – Assessment procedure description



# TESTS – Assessment procedure description



# TESTS

## Assessment procedure description

### Pre-conditioning period:

all the desired temperatures and flow rates are set in the testing bench and measured.

### Start-up period:

Once the temperature levels desired are reached in the tanks, cycling operation of the storage is started. All the parameters are recorded for a duration of at least 5 charge/discharge cycles.

### Steady-state period:

The data recorded – for the last 3 cycles - are used for data analysis. Correspondence between the temperature levels set and measured is constantly checked.

### Data analysis:

The data collected during the steady-state period are used for the calculation of the key figures selected.

Consiglio Nazionale delle Ricerche



**TASK 48**

Cold storage	
Discharge power (DP)	$PD = \frac{\int_0^{t_{ev}} \dot{m}_{pc} c_p (T_{in,pc} - T_{out,pc}) dt}{t_{ev}}$ [W]
Stored Energy (SE)	$SE = \int_0^{t_{ev}} \dot{m}_{pc} c_p (T_{in,pc} - T_{out,pc}) dt$ [Wh]
Storage Energy Density (SED)	$SED = \frac{SE}{m_{adsorbent}} \left[ \frac{Wh}{kg} \right]$
Storage efficiency ( $\eta$ )	$\eta = \frac{\int_0^{t_{ev}} \dot{m}_{pc} c_p (T_{in,pc} - T_{out,pc}) dt}{\int_0^{t_{des}} \dot{m}_{ads} c_p (T_{in,ads} - T_{out,ads}) dt}$
Long- term heat storage	
Discharge power (DP)	$PD = \frac{\int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}{t_{adsorption}}$ [W]
Stored Energy (SE)	$SE = \int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt$ [Wh]
Storage Energy Density (SED)	$SED = \frac{SE}{m_{adsorbent}} \left[ \frac{Wh}{kg} \right]$
Storage efficiency ( $\eta$ )	$\eta = \frac{\int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}{\int_0^{t_{des}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}$
Short- term heat storage	
Discharge power (DP)	$PD = \frac{\int_0^{t_{cond}} \dot{m}_{pc} c_p (T_{out,pc} - T_{in,pc}) dt + \int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}{t_{cond} + t_{adsorption}}$ [W]
Stored Energy (SE)	$SE = \int_0^{t_{cond}} \dot{m}_{pc} c_p (T_{out,pc} - T_{in,pc}) dt + \int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt$ [Wh]
Storage Energy Density (SED)	$SED = \frac{SE}{m_{adsorbent}} \left[ \frac{Wh}{kg} \right]$
Storage efficiency ( $\eta$ )	$PD = \frac{\int_0^{t_{cond}} \dot{m}_{pc} c_p (T_{out,pc} - T_{in,pc}) dt + \int_0^{t_{adsorption}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}{\int_0^{t_{des}} \dot{m}_{ads} c_p (T_{out,ads} - T_{in,ads}) dt}$

# TESTS – Results

AVERAGE POWER DURING  
DISCHARGING PHASE:

**Up to 520 W**

STORED COLD ENERGY:

**< 590 Wh**

**< 132 Wh/kg**

Test	Cycle	HT_in °C	ADS_av °C	MT_in °C	LT_in °C	t_charge s	t_discharge s	Delta °C	W_disch W	E Wh
3	1	88.59	34.91	33.91	14.93	3600.00	3600.00	18.98	415.86	418.86
	2	88.57	34.66	33.55	15.27	3600.00	3600.00	18.27	387.60	396.22
4	1	89.49	33.93	33.66	14.72	4500.00	4500.00	18.94	342.38	452.46
5	1	89.35	34.14	33.56	20.08	4500.00	4500.00	13.48	405.92	521.66
6	1	89.37	34.35	34.03	19.90	4500.00	4500.00	14.13	475.69	590.91
	2	89.38	34.20	34.12	20.42	4500.00	4500.00	13.70	493.24	571.34
7	1	87.11	38.32	38.15	19.84	4500.00	4500.00	18.31	424.15	556.47
	2	87.38	37.39	35.59	19.86	4500.00	4500.00	15.74	373.29	491.33
8	1	85.67	34.91	33.65	19.68	2700.00	2700.00	13.97	518.86	428.61
	2	86.56	36.68	33.00	20.44	2700.00	2700.00	12.56	487.86	401.91
	3	87.41	36.57	31.54	21.28	2700.00	2700.00	10.26	481.91	399.15

30 different measuring points  
> 250 total tests




27	1	89.83	33.87	32.89	16.22	3600.00	3600.00	16.67	222.16	204.98
	2	89.92	33.59	32.67	16.45	3600.00	3600.00	16.22	181.55	170.90
28	1	89.23	32.18	28.62	21.08	2700.00	2700.00	7.54	367.07	265.69
	2	89.31	32.66	26.27	21.86	2700.00	2700.00	4.41	406.00	395.31
29	1	89.91	31.24	29.54	17.18	2700.00	2700.00	12.36	426.69	351.09
	2	89.94	31.06	29.11	17.39	2700.00	2700.00	11.73	385.13	312.74
	3	90.18	30.81	29.07	16.90	2700.00	2700.00	12.17	344.90	263.36
30	1	88.99	40.85	40.12	17.95	3600.00	3600.00	22.17	201.96	108.14



# TESTS – Results



Discharging Time: 45 – 60 mins



Consiglio Nazionale delle Ricerche

# TESTS – Results




- 28 % respect to the design

Thermal Losses OVER-ESTIMATED

TARGET


112 Wh/kg  
~ 400 kJ/kg



- ◇ Energy 90/35/15
- ◇ Energy 90/30/17
- ◆ Power\_90/35/15
- ◆ Power 90/30/17

# ENERGY BALANCE

Consiglio Nazionale delle Ricerche



**A 15% improvement in storage efficiency could be obtained by improving thermal insulation or reducing the amount of metal**

**(for example, choosing a cylindrical shape with very thin wall or replacing stainless steel with lightweight non-metallic materials)**







# CONCLUSIONS

- ❑ A sorption cold storage system, using FAM Z02 Zeolite, for application in telecommunication has been designed, identifying the following desired performance and boundary conditions:



**2 kWh cold storage capacity, 1 kW avg. power, charge @95 °C, discharge (cold useful effect) @ 10-17 °C.**

- ❑ A reduced size lab scale system has been designed, realized and tested.
- ❑ A tentative assessment procedure has been defined and used to partially characterize the lab scale sorption cold storage system (→ T48).
- ❑ Results showed that the system realized and tested is capable to deliver up to 500 W as avg. cooling power at the selected operating conditions and to store up to 590 Wh of cold. Accordingly the energy density measured is 400 kJ/kg (112 Wh/kg).
- ❑ More tests and improvements are needed.

# NEXT ACTIVITIES

-  Tests on long term storage (1 week and more)
-  Improve the testing station → Long Term Tests
-  Codify the procedure (ANNEX 30?)
-  Test new composite materials (SWS family)
-  Investigate corrosion issues 

# Heat storage: Vermiculite/LiCl - water



Consiglio Nazionale delle Ricerche



*Vermiculite/LiCl  
lamella HEX  
adsorber*

**First experimental results: Average heating power c.a. 350 W for about ½ hour. Peak power 1.8 kW. Energy storage density: **164 kWh/kg\_ads** (theoretical 417 kWh/kg)**

# THANK YOU FOR THE KIND ATTENTION!



**STI Research Group is:**

**Vincenza Brancato, Andrea Frazzica, Davide La Rosa, Gaetano Maggio, Valeria Palomba, Alessio Sapienza and Salvatore Vasta**

## Salvatore Vasta

Consiglio Nazionale delle Ricerche (CNR)  
Istituto di Tecnologie Avanzate per l'Energia "Nicola Giordano" (ITAE)  
**CENTROPROVE**  
Via Comunale S. Lucia n. 40  
98126 S. Lucia, Messina, ITALY

P: +39.090.624.404 - F: +39.090.624.247

Skype: salvo-vasta

W: [www.itae.cnr.it](http://www.itae.cnr.it) - E: [salvatore.vasta@itae.cnr.it](mailto:salvatore.vasta@itae.cnr.it)



<https://centroprove.wordpress.com/>

